

ADDENDUM #1 - APRIL 29, 2011

RE: **GINSBURG-BROWN RESIDENCE
PROJECT #10.90**

FROM: HGE INC., Architects, Engineers, Surveyors & Planners
375 Park Avenue
Coos Bay, Oregon 97420
541-269-1166



TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated April 2011, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page.

CHANGES TO PROJECT MANUAL

1. Division 16, Electrical - 16D.02.a. Change typical recessed lights to:

Progress P84 -AT Housing. Trim clear Alzak trim. P8368-21A. (Fixture appropriate for insulated installation.) Provide 26 watt compact fluorescent at regular switches, and 75 watt incandescent at dimmable switches.

2. Division 16, Electrical 16E.04. Electric Radiant Floor Heating System. Increase electric radiant floor heating zones to approximately 15 per manufacturer's recommendations.

END OF ADDENDUM